




Building
Safety
Certificate

Little Angels English
Medium School,
Malegaon



BUILDING SAFETY CERTIFICATE

Letter O. No : 131/P/25

Dated : 05/Aug/2025

It is certified that the existing building **Little Angels English Medium School** at **Sr No-333/1+2+3, Plot No- 12+13 & 23+24, Vardhaman Nagar, Sangameshwar, Malegaon.**

The building is owned/occupied by **Little Angels Educational Society** have complied with the Building safety requirements in accordance with National Building Code Rules, and verified by the concerned of **Parvati Consultants** on dated **31/July/2025** in the presence of Mr. Khandusing Pardeshi (his representative) and that the **building/premises is fit for occupancy for running school** with effect from **Aug-2025** for a period of **03 years** in accordance with rule and subject to compliance of the specific conditions as appended.

➤ Recommendations

1. We have found wall deterioration at ground floor staircase, second floor washroom and found wall punning minor crack at office wall.
2. All the deterioration & minor cracks should be chaser in line & fill with the Dr. Fixit crack filler.
3. Remove the damp deteriorate surface.
4. Apply Dr fixit damp guard over removed surface.
5. Apply weatherproof paint over repair surface.
5. Periodic maintenance of overall building should be done regularly.

➤ Notes

1. The statutory requirement is to conduct a structural audit after 3 years.



Name & Signature of Auditor
Er Khemraj S. Deore
Consulting Structural Engineer .
Parvati Consultants
(Dip-Civil, BE-Civil, ME-Structure, Fiv-Valuation, I.I.E)
Issued On Date – 05/Aug/2025
Place - Malegaon

Approved Authority Licenses
MMC- DDMMC/R/2021/APL/00217
Indian Inst. Engg I.I.E.– AM1781564
Pub. Works Dept.PWD -41AXC63Z7G
Zillah Parishad ZP – 1832/2018